



Carlos Rosario PCS (Harvard Street) - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Carlos Rosario PCS [Harvard Street]	WS-003-001	Food Prep Sink	Basement	In kitchen		Right	WF-082019-003001-02	11/4/2019	FT-FY20-082019-003001-A	<1	FT-FY20-082019-003001-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-003	Cooler	Basement	In hallway adjacent to room LL17	Low	Left	WF-082019-003003-02	11/4/2019	FT-FY20-082019-003003-A	<1	FT-FY20-082019-003003-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-004	Cooler	Basement	In hallway adjacent to room LL17	High	Right	WF-082019-003004-02	11/4/2019	FT-FY20-082019-003004-A	<1	FT-FY20-082019-003004-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-006	Cooler	2	In hallway adjacent to room 224	High	Right	WF-082019-003006-02	11/4/2019	FT-FY20-082019-003006-A	<1	FT-FY20-082019-003006-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-007	Cooler	1	In hallway adjacent to room 120A	Low	Left	WF-082019-003007-02	11/4/2019	FT-FY20-082019-003007-A	<1	FT-FY20-082019-003007-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-008	Cooler	1	In hallway adjacent to room 120A	High	Right	WF-082019-003008-02	11/4/2019	FT-FY20-082019-003008-A	<1	FT-FY20-082019-003008-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-009	Ice Maker	Basement	In kitchen			WF-082019-003009-02	11/4/2019	FT-FY20-082019-003009-A	<1	FT-FY20-082019-003009-B	<1