



Carlos Rosario PCS (Sonia Gutierrez) - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-001	Cooler	Ground	In hallway adjacent to room SG012	High	Left	WF-082019-043001-02	10/16/2019	FT-FY20-082019-043001-A	<1	FT-FY20-082019-043001-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-002	Bottle Filler	Ground	In hallway adjacent to room SG012	High	Left	WF-082019-043002-02	10/16/2019	FT-FY20-082019-043002-A	<1	FT-FY20-082019-043002-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-003	Cooler	Ground	In hallway adjacent to room SG012	Low	Right	WF-082019-043003-02	10/16/2019	FT-FY20-082019-043003-A	<1	FT-FY20-082019-043003-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-004	Cooler	1	In hallway adjacent to room SG107	High	Left	WF-082019-043004-02	10/16/2019	FT-FY20-082019-043004-A	<1	FT-FY20-082019-043004-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-005	Bottle Filler	1	In hallway adjacent to room SG107	High	Left	WF-082019-043005-02	10/16/2019	FT-FY20-082019-043005-A	<1	FT-FY20-082019-043005-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-006	Cooler	1	In hallway adjacent to room SG107	Low	Right	WF-082019-043006-02	10/16/2019	FT-FY20-082019-043006-A	<1	FT-FY20-082019-043006-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-007	Cooler	2	In hallway adjacent to room 209	High	Left	WF-082019-043007-02	10/16/2019	FT-FY20-082019-043007-A	<1	FT-FY20-082019-043007-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-008	Bottle Filler	2	In hallway adjacent to room 209	High	Left	WF-082019-043008-02	10/16/2019	FT-FY20-082019-043008-A	<1	FT-FY20-082019-043008-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-009	Cooler	2	In hallway adjacent to room 209	Low	Right	WF-082019-043009-02	10/16/2019	FT-FY20-082019-043009-A	<1	FT-FY20-082019-043009-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-012	Break Room	2	In staff lounge 217			WF-082019-043012-02	10/16/2019	FT-FY20-082019-043012-A	<1	FT-FY20-082019-043012-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-013	Cooler	3	In hallway adjacent to room 319	High	Left	WF-082019-043013-02	10/16/2019	FT-FY20-082019-043013-A	<1	FT-FY20-082019-043013-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-014	Bottle Filler	3	In hallway adjacent to room 319	High	Left	WF-082019-043014-02	10/16/2019	FT-FY20-082019-043014-A	<1	FT-FY20-082019-043014-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-015	Cooler	3	In hallway adjacent to room 319	Low	Right	WF-082019-043015-02	10/16/2019	FT-FY20-082019-043015-A	<1	FT-FY20-082019-043015-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-016	Health Suite	3	In nurse suite 311A			WF-082019-043016-02	10/16/2019	FT-FY20-082019-043016-A	<1	FT-FY20-082019-043016-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-017	Cooler	3	In main hall 325	High	Left	WF-082019-043017-02	10/16/2019	FT-FY20-082019-043017-A	<1	FT-FY20-082019-043017-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-018	Bottle Filler	3	In main hall 325	High	Left	WF-082019-043018-02	10/16/2019	FT-FY20-082019-043018-A	<1	FT-FY20-082019-043018-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-019	Cooler	3	In main hall 325	Low	Right	WF-082019-043019-02	10/16/2019	FT-FY20-082019-043019-A	<1	FT-FY20-082019-043019-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-020	Food Prep Sink	3	In SG 306 by window			WF-082019-043020-02	10/16/2019	FT-FY20-082019-043020-A	<1	FT-FY20-082019-043020-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-021	Bottle Filler	2	In room SG 220			WF-082019-043021-02	10/16/2019	FT-FY20-082019-043021-A	<1	FT-FY20-082019-043021-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-022	Bottle Filler	2	In break room SG 217			WF-082019-043022-02	10/16/2019	FT-FY20-082019-043022-A	<1	FT-FY20-082019-043022-B	<1