



Carlos Rosario PCS [Harvard Street] - Lead in Water Test Results



FY21 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Carlos Rosario PCS [Harvard Street]	WS-003-003	Cooler	Basement	in hallway adjacent to room LL17	Low	Left	WF-012021-003003-04	N/A	FT-FY21-012021-003003-A	Non-Op	FT-FY21-012021-003003-B	Non-Op
Carlos Rosario PCS [Harvard Street]	WS-003-004	Cooler	Basement	in hallway adjacent to room LL17	High	Right	WF-012021-003004-04	N/A	FT-FY21-012021-003004-A	Non-Op	FT-FY21-012021-003004-B	Non-Op
Carlos Rosario PCS [Harvard Street]	WS-003-005	Cooler	2	in hallway adjacent to room 224	Low	Left	WF-012021-003005-04	N/A	FT-FY21-012021-003005-A	Non-Op	FT-FY21-012021-003005-B	Non-Op
Carlos Rosario PCS [Harvard Street]	WS-003-006	Cooler	2	in hallway adjacent to room 224	High	Right	WF-012021-003006-04	N/A	FT-FY21-012021-003006-A	Non-Op	FT-FY21-012021-003006-B	Non-Op
Carlos Rosario PCS [Harvard Street]	WS-003-007	Cooler	1	in hallway adjacent to room 120A	Low	Left	WF-012021-003007-04	N/A	FT-FY21-012021-003007-A	Non-Op	FT-FY21-012021-003007-B	Non-Op
Carlos Rosario PCS [Harvard Street]	WS-003-008	Cooler	1	in hallway adjacent to room 120A	High	Right	WF-012021-003008-04	N/A	FT-FY21-012021-003008-A	Non-Op	FT-FY21-012021-003008-B	Non-Op
Carlos Rosario PCS [Harvard Street]	WS-003-009	Ice Maker	Basement	in kitchen			WF-012021-003009-04	6/23/2021	FT-FY21-012021-003009-A	<1	FT-FY21-012021-003009-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-010	Bottle Filler	Basement	in hallway adjacent to room LL17			WF-012021-003010-01	6/23/2021	FT-FY21-012021-003010-A	<1	FT-FY21-012021-003010-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-011	Bottle Filler	1	in hallway adjacent to room 120A			WF-012021-003011-01	6/23/2021	FT-FY21-012021-003011-A	<1	FT-FY21-012021-003011-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-012	Bottle Filler	2	in hallway adjacent to room 224			WF-012021-003012-01	6/23/2021	FT-FY21-012021-003012-A	<1	FT-FY21-012021-003012-B	<1

Greater than 5 ppb - Devices Requiring Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Carlos Rosario PCS [Harvard Street]	WS-003-002	Food Prep Sink	Basement	in kitchen next to the ice maker			WF-012021-003002-04	6/23/2021	FT-FY21-012021-003002-A	51.0	FT-FY21-012021-003002-B	3.9
Carlos Rosario PCS [Harvard Street]	WS-003-001	Food Prep Sink	Basement	in kitchen		Right	WF-012021-003001-04	6/23/2021	FT-FY21-012021-003001-A	14	FT-FY21-012021-003001-B	<1

Less than 5 ppb - Devices Requiring No Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Carlos Rosario PCS [Harvard Street]	WS-003-002	Food Prep Sink	Basement	in kitchen next to the ice maker			WF-072021-003002-05	7/8/2021	FT-FY21-072021-003002-A	2.9	FT-FY21-072021-003002-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-001	Food Prep Sink	Basement	in kitchen		Right	WF-072021-003001-05	7/8/2021	FT-FY21-072021-003001-A	<1	FT-FY21-072021-003001-B	<1