



Carlos Rosario PCS (Sonia Gutierrez) - Lead in Water Test Results



FY23 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-001	Cooler	Ground	in hallway adjacent to room SG012	High	Left	WF-012023-043001-06	N/A	FT-FY23-012023-043001-A	Non-operational	FT-FY23-012023-043001-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-002	Bottle Filler	Ground	in hallway adjacent to room SG012	High	Left	WF-012023-043002-06	4/11/23	FT-FY23-012023-043002-A	<1	FT-FY23-012023-043002-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-003	Cooler	Ground	in hallway adjacent to room SG012	Low	Right	WF-012023-043003-06	N/A	FT-FY23-012023-043003-A	Non-operational	FT-FY23-012023-043003-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-004	Cooler	1	in hallway adjacent to room SG107	High	Left	WF-012023-043004-06	N/A	FT-FY23-012023-043004-A	Non-operational	FT-FY23-012023-043004-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-005	Bottle Filler	1	in hallway adjacent to room SG107	High	Left	WF-012023-043005-06	4/11/23	FT-FY23-012023-043005-A	<1	FT-FY23-012023-043005-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-006	Cooler	1	in hallway adjacent to room SG107	Low	Right	WF-012023-043006-06	N/A	FT-FY23-012023-043006-A	Non-operational	FT-FY23-012023-043006-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-007	Cooler	2	in hallway adjacent to room 209	High	Left	WF-012023-043007-06	N/A	FT-FY23-012023-043007-A	Non-operational	FT-FY23-012023-043007-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-008	Bottle Filler	2	in hallway adjacent to room 209	High	Left	WF-012023-043008-06	4/11/23	FT-FY23-012023-043008-A	<1	FT-FY23-012023-043008-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-009	Cooler	2	in hallway adjacent to room 209	Low	Right	WF-012023-043009-06	N/A	FT-FY23-012023-043009-A	Non-operational	FT-FY23-012023-043009-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-012	Break Room	2	in staff lounge 217			WF-012023-043012-06	4/11/23	FT-FY23-012023-043012-A	<1	FT-FY23-012023-043012-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-013	Cooler	3	in hallway adjacent to room 319	High	Left	WF-012023-043013-06	N/A	FT-FY23-012023-043013-A	Non-operational	FT-FY23-012023-043013-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-014	Bottle Filler	3	in hallway adjacent to room 319	High	Left	WF-012023-043014-06	4/11/23	FT-FY23-012023-043014-A	<1	FT-FY23-012023-043014-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-015	Cooler	3	in hallway adjacent to room 319	Low	Right	WF-012023-043015-06	N/A	FT-FY23-012023-043015-A	Non-operational	FT-FY23-012023-043015-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-016	Health Suite	3	in nurse suite 311A			WF-012023-043016-06	4/11/23	FT-FY23-012023-043016-A	<1	FT-FY23-012023-043016-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-017	Cooler	3	in main hall 325	High	Left	WF-012023-043017-06	N/A	FT-FY23-012023-043017-A	Non-operational	FT-FY23-012023-043017-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-018	Bottle Filler	3	in main hall 325	High	Left	WF-012023-043018-06	4/11/23	FT-FY23-012023-043018-A	<1	FT-FY23-012023-043018-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-019	Cooler	3	in main hall 325	Low	Right	WF-012023-043019-06	N/A	FT-FY23-012023-043019-A	Non-operational	FT-FY23-012023-043019-B	Non-operational
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-020	Food Prep Sink	3	in SG 306 by window			WF-012023-043020-06	4/11/23	FT-FY23-012023-043020-A	<1	FT-FY23-012023-043020-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-021	Bottle Filler	2	in room SG 220			WF-012023-043021-06	4/11/23	FT-FY23-012023-043021-A	<1	FT-FY23-012023-043021-B	<1
Carlos Rosario PCS [Sonia Gutierrez]	WS-043-022	Bottle Filler	2	in break room SG 217			WF-012023-043022-06	4/11/23	FT-FY23-012023-043022-A	<1	FT-FY23-012023-043022-B	<1