



Carlos Rosario PCS (Harvard Street) - Lead in Water Test Results



FY25 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Carlos Rosario PCS [Harvard Street]	WS-003-001	Food Prep Sink	Basement	In kitchen		Right	WF-012025-003001-09	5/13/2025	FT-FY25-012025-003001-A	<1	FT-FY25-012025-003001-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-003	Cooler	Basement	In hallway adjacent to room LL17	Low	Left	WF-012025-003003-08	5/13/2025	FT-FY25-012025-003003-A	<1	FT-FY25-012025-003003-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-004	Cooler	Basement	In hallway adjacent to room LL17	High	Right	WF-012025-003004-08	5/13/2025	FT-FY25-012025-003004-A	<1	FT-FY25-012025-003004-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-005	Cooler	2	In hallway adjacent to room 224	Low	Left	WF-012025-003005-08	5/13/2025	FT-FY25-012025-003005-A	<1	FT-FY25-012025-003005-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-006	Cooler	2	In hallway adjacent to room 224	High	Right	WF-012025-003006-08	5/13/2025	FT-FY25-012025-003006-A	<1	FT-FY25-012025-003006-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-007	Cooler	1	In hallway adjacent to room 120A	Low	Left	WF-012025-003007-08	5/13/2025	FT-FY25-012025-003007-A	<1	FT-FY25-012025-003007-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-008	Cooler	1	In hallway adjacent to room 120A	High	Right	WF-012025-003008-08	5/13/2025	FT-FY25-012025-003008-A	<1	FT-FY25-012025-003008-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-009	Ice Maker	Basement	In kitchen			WF-012025-003009-08	5/13/2025	FT-FY25-012025-003009-A	<1	FT-FY25-012025-003009-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-010	Bottle Filler	Basement	In hallway adjacent to room LL17			WF-012025-003010-05	5/13/2025	FT-FY25-012025-003010-A	<1	FT-FY25-012025-003010-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-011	Bottle Filler	1	In hallway adjacent to room 120A			WF-012025-003011-05	5/13/2025	FT-FY25-012025-003011-A	<1	FT-FY25-012025-003011-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-012	Bottle Filler	2	In hallway adjacent to room 224			WF-012025-003012-05	5/13/2025	FT-FY25-012025-003012-A	<1	FT-FY25-012025-003012-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-013	Bottle Filler	1	In staff lounge 112			WF-012025-003013-04	5/13/2025	FT-FY25-012025-003013-A	<1	FT-FY25-012025-003013-B	<1
Carlos Rosario PCS [Harvard Street]	WS-003-014	Break Room	1	In staff lounge 112			WF-012025-003014-01	5/13/2025	FT-FY25-012025-003014-A	<1	FT-FY25-012025-003014-B	<1